

PEARL Reconditioning Standards			
EXPLOSION PROOF CONDUIT SEALING CEMENT AND FIBER	Revision		
	Standard	Number	Date
	5390	5	11-2008

This guideline pertains to the sale and distribution of explosion proof conduit sealing cement and fiber.

I INSPECTION

These steps are used to determine what will be required to recondition this product under this standard.

1 INSPECTION

1.1 Conduit Sealing Cement and Fiber

- 1.1.1** Inspect for signs of deterioration and moisture.
- 1.1.2** Inspect for incorrect weight of contents.
- 1.1.3** Discard defective or substandard material.

II RECONDITIONING AND QUALITY CONTROL PROCEDURES

The following procedures are in a recommended order and are required to recondition this product. PEARL recognizes that, based upon actual product design and/or as found condition, some of these procedures may not be applicable.

1 RECONDITIONING

1.1 Conduit Sealing Cement and Fiber

- 1.1.1** Ensure that the package contents weight is correct.

1.2 Packaging and Labeling

- 1.2.1** Ensure that the package label is complete, correct and legible.

III PEARL CERTIFICATION

This product has now been reconditioned under the PEARL Reconditioning Standard. The blue PEARL Reconditioning Quality Seal or PEARL stamp may now be placed on the device or its packaging.