

PEARL Reconditioning Standards			
METAL CONDUIT FITTINGS NIPPLES -THREADED COUPLINGS-ELBOWS	Revision		
	Standard	Number	Date
	5110	5	11-2008

This guideline pertains to the sale and distribution of metal conduit nipples, threaded couplings, elbows and related materials. All metal conduit nipples, threaded couplings, elbows and related materials sold through distribution are to be new and unused.

I INSPECTION

These steps are used to determine what will be required to recondition this product under this standard.

1 INSPECTION

1.1 Conduit Nipples, Threaded Couplings, Elbows and Components

- 1.1.1** Ensure that the product identifier marking is legible, if applicable.
- 1.1.2** Inspect for signs of damage, deterioration and defects.
- 1.1.3** Inspect thread protectors for signs of damage, deterioration and defects, if applicable.
- 1.1.4** Discard defective or substandard material.

II RECONDITIONING AND QUALITY CONTROL PROCEDURES

The following procedures are in a recommended order and are required to recondition this product. PEARL recognizes that, based upon actual product design and/or as found condition, some of these procedures may not be applicable.

1 RECONDITIONING

1.1 Conduit Nipples, Threaded Couplings, Elbows and Components

- 1.1.1** Clean all parts.
- 1.1.2** Refinish, as necessary.
- 1.1.3** Replace thread protectors with new, as necessary.
- 1.1.4** Repair or replace damaged or incorrect product identifier to reflect proper information.

1.2 Packaging and Labeling

- 1.2.1** Ensure that the package label is complete, correct and legible.

III PEARL CERTIFICATION

This product has now been reconditioned under the PEARL Reconditioning Standard. The blue PEARL Reconditioning Quality Seal or PEARL stamp may now be placed on the device or its packaging.