

PEARL Reconditioning Standards			
NON-METALLIC CONDUIT FITTINGS CONNECTORS AND ADAPTERS	Revision		
	Standard	Number	Date
	5230	3	11-2008

This guideline pertains to the sale and distribution of non-metallic conduit connectors and adapters. All non-metallic conduit connectors and adapters sold through distribution are to be new and unused.

I INSPECTION

These steps are used to determine what will be required to recondition this product under this standard.

1 INSPECTION

1.1 Conduit Connectors, Adapters and Components

- 1.1.1** Ensure that the product identifier marking is legible, if applicable.
- 1.1.2** Inspect for signs of damage, deterioration and defects.
- 1.1.3** Discard defective or substandard material.

II RECONDITIONING AND QUALITY CONTROL PROCEDURES

The following procedures are in a recommended order and are required to recondition this product. PEARL recognizes that, based upon actual product design and/or as found condition, some of these procedures may not be applicable.

1 RECONDITIONING

1.1 Conduit Connectors, Adapters and Components

- 1.1.1** Clean all parts.
- 1.1.2** Repair or replace damaged, defective or missing component parts.
- 1.1.3** Repair or replace damaged or incorrect product identifier to reflect proper information.

1.2 Packaging and Labeling

- 1.2.1** Ensure that the package label is complete, correct and legible.

III PEARL CERTIFICATION

This product has now been reconditioned under the PEARL Reconditioning Standard. The blue PEARL Reconditioning Quality Seal or PEARL stamp may now be placed on the device or its packaging.