

PEARL Reconditioning Standards			
NON-METALLIC CONDUIT PVC CEMENT	Revision		
	Standard	Number	Date
	5290	5	11-2008

This guideline pertains to the sale and distribution of non-metallic conduit PVC cement.

I INSPECTION

These steps are used to determine what will be required to recondition this product under this standard.

1 INSPECTION

1.1 Conduit Cement

- 1.1.1** Inspect for signs of deterioration and contamination.
- 1.1.2** Inspect for incorrect weight of contents.
- 1.1.3** Inspect date code, if applicable.
- 1.1.4** Discard defective, substandard or expired material.

II RECONDITIONING AND QUALITY CONTROL PROCEDURES

The following procedures are in a recommended order and are required to recondition this product. PEARL recognizes that, based upon actual product design and/or as found condition, some of these procedures may not be applicable.

1 RECONDITIONING

1.1 Conduit Cement

- 1.1.1** Ensure that the container is properly sealed and leak-proof.
- 1.1.2** Ensure that the contents weight is correct.

1.2 Packaging and Labeling

- 1.2.1** Ensure that the package label is complete, correct and legible.

III PEARL CERTIFICATION

This product has now been reconditioned under the PEARL Reconditioning Standard. The blue PEARL Reconditioning Quality Seal or PEARL stamp may now be placed on the device or its packaging.