

<b>PEARL Reconditioning Standards</b>			
<b>PVC COATED METAL CONDUIT FITTINGS LIQUID TIGHT CONDUIT CONNECTORS</b>	Revision		
	Standard	Number	Date
	<b>5450</b>	5	11-2008

This guideline pertains to the sale and distribution of PVC coated metal liquid tight conduit connectors and related parts.

## **I INSPECTION**

These steps are used to determine what will be required to recondition this product under this standard.

### **1 INSPECTION**

#### **1.1 Liquid Tight Conduit Connectors and Components**

- 1.1.1** Ensure that the product identifier marking is legible, if applicable.
- 1.1.2** Inspect for signs of damage, deterioration and defects.
- 1.1.3** Discard defective or substandard material.

## **II RECONDITIONING AND QUALITY CONTROL PROCEDURES**

The following procedures are in a recommended order and are required to recondition this product. PEARL recognizes that, based upon actual product design and/or as found condition, some of these procedures may not be applicable.

### **1 RECONDITIONING**

#### **1.1 Liquid Tight Conduit Connectors and Components**

- 1.1.1** Clean all parts.
- 1.1.2** Refinish, as necessary.
- 1.1.3** Repair damaged PVC coating with approved PVC patch, as necessary.
- 1.1.4** Repair or replace damaged, defective or missing component parts.
- 1.1.5** Repair or replace damaged or incorrect product identifier to reflect proper information.

#### **1.2 Packaging and Labeling**

- 1.2.1** Ensure that the package label is complete, correct and legible.

## **III PEARL CERTIFICATION**

This product has now been reconditioned under the PEARL Reconditioning Standard. The blue PEARL Reconditioning Quality Seal or PEARL stamp may now be placed on the device or its packaging.