

PEARL Reconditioning Standards			
PVC COATED METAL CONDUIT FITTINGS DEFLECTION AND EXPANSION	Revision		
	Standard	Number	Date
	5460	5	11-2008

This guideline pertains to the sale and distribution of PVC coated metal conduit deflection and expansion fittings and related parts.

I INSPECTION

These steps are used to determine what will be required to recondition this product under this standard.

1 INSPECTION

1.1 Conduit Deflection and Expansion Fittings and Components

- 1.1.1** Ensure that the product identifier marking is legible, if applicable.
- 1.1.2** Inspect for signs of damage, deterioration and defects.
- 1.1.3** Inspect for incorrect and missing parts.
- 1.1.4** Discard defective or substandard material.

II RECONDITIONING AND QUALITY CONTROL PROCEDURES

The following procedures are in a recommended order and are required to recondition this product. PEARL recognizes that, based upon actual product design and/or as found condition, some of these procedures may not be applicable.

1 RECONDITIONING

1.1 Conduit Deflection and Expansion Fittings and Components

- 1.1.1** Clean all parts.
- 1.1.2** Refinish, as necessary.
- 1.1.3** Repair damaged PVC coating with approved PVC patch, as necessary.
- 1.1.4** Repair or replace damaged, defective, incorrect or missing component parts.
- 1.1.5** Repair or replace damaged or incorrect product identifier to reflect proper information.

1.2 Packaging and Labeling

- 1.2.1** Ensure that the package label is complete, correct and legible.

III PEARL CERTIFICATION

This product has now been reconditioned under the PEARL Reconditioning Standard. The blue PEARL Reconditioning Quality Seal or PEARL stamp may now be placed on the device or its packaging.