

<b>PEARL Reconditioning Standards</b>			
<b>NON-METALLIC CONDUIT FITTINGS NIPPLES-COUPPLINGS-ELBOWS</b>	Revision		
	Section	Number	Date
	<b>5210</b>	3	2-11-03

This guideline pertains to the sale and distribution of non-metallic conduit nipples, couplings and elbows. All non-metallic conduit nipples, couplings and elbows sold through distribution are to be new and unused.

## **I INSPECTION**

These steps are used to determine what will be required to recondition this product under this standard.

### **1 INSPECTION**

#### **1.1 Conduit Nipples, Couplings and Elbows and Components**

- 1.1.1** Ensure that the product identifier marking is legible, if applicable.
- 1.1.2** Inspect for signs of damage, deterioration and defects.
- 1.1.3** Discard defective or substandard material.

## **II RECONDITIONING AND QUALITY CONTROL PROCEDURES**

The following procedures are in a recommended order and are required to recondition this product. PEARL recognizes that, based upon actual product design and/or as found condition, some of these procedures may not be applicable.

### **1 RECONDITIONING**

#### **1.1 Conduit Nipples, Couplings and Elbows and Components**

- 1.1.1** Clean all parts.
- 1.1.2** Repair or replace damaged or incorrect product identifier to reflect proper information.

#### **1.2 Packaging and Labeling**

- 1.2.1** Ensure that the package label is complete, correct and legible.

## **III PEARL CERTIFICATION**

This product has now been reconditioned under the PEARL Reconditioning Standard. The PEARL label and/or seal may be placed on it or its packaging.