

| <b>PEARL Reconditioning Standards</b>                           |             |        |         |
|---|-------------|--------|---------|
| <b>EXPLOSION PROOF<br/>CONDUIT<br/>SEALING CEMENT AND FIBER</b> | Revision    |        |         |
|   | Section     | Number | Date    |
|   | <b>5390</b> | 3      | 2-11-03 |

This guideline pertains to the sale and distribution of explosion proof conduit sealing cement and fiber.

## **I INSPECTION**

These steps are used to determine what will be required to recondition this product under this standard.

### **1 INSPECTION**

#### **1.1 Conduit Sealing Cement and Fiber**

- 1.1.1** Inspect for signs of deterioration and moisture.
- 1.1.2** Inspect for incorrect weight of contents.
- 1.1.3** Discard defective or substandard material.

## **II RECONDITIONING AND QUALITY CONTROL PROCEDURES**

The following procedures are in a recommended order and are required to recondition this product. PEARL recognizes that, based upon actual product design and/or as found condition, some of these procedures may not be applicable.

### **1 RECONDITIONING**

#### **1.1 Conduit Sealing Cement and Fiber**

- 1.1.1** Ensure that the package contents weight is correct.

#### **1.2 Packaging and Labeling**

- 1.2.1** Ensure that the package label is complete, correct and legible.

## **III PEARL CERTIFICATION**

This product has now been reconditioned under the PEARL Reconditioning Standard. The PEARL label and/or seal may be placed on it or its packaging.