

PEARL Reconditioning Standards		
PVC COATED METAL CONDUIT	Revision	
	Section	Number
	5405	3
		Date
		2-11-03

This guideline pertains to the sale and distribution of PVC coated metal conduit. All PVC coated metal conduit sold through distribution is to be new and unused.

I INSPECTION

These steps are used to determine what will be required to recondition this product under this standard.

1 INSPECTION

1.1 Conduit

- 1.1.1 Ensure that the product identifier marking is legible, if applicable.
- 1.1.2 Inspect for signs of damage, deterioration and defects.
- 1.1.3 Inspect thread protectors for signs of damage, deterioration and defects.
- 1.1.4 Discard defective or substandard material.

II RECONDITIONING AND QUALITY CONTROL PROCEDURES

The following procedures are in a recommended order and are required to recondition this product. PEARL recognizes that, based upon actual product design and/or as found condition, some of these procedures may not be applicable.

1 RECONDITIONING

1.1 Conduit

- 1.1.1 Clean all parts.
- 1.1.2 Refinish, as necessary.
- 1.1.3 Repair damaged PVC coating with approved PVC patch, as necessary.
- 1.1.4 Replace thread protectors with new, as necessary.
- 1.1.5 Repair or replace damaged or incorrect product identifier to reflect proper information.

1.2 Packaging and Labeling

- 1.2.1 Ensure that the package label is complete, correct and legible.

III PEARL CERTIFICATION

This product has now been reconditioned under the PEARL Reconditioning Standard. The PEARL label and/or seal may be placed on it or its packaging.