

PEARL Reconditioning Standards			
PVC COATED METAL CONDUIT FITTINGS OUTLET BODIES	Revision		
	Section	Number	Date
	5420	3	2-11-03

This guideline pertains to the sale and distribution of PVC coated metal conduit outlet bodies and related parts.

I INSPECTION

These steps are used to determine what will be required to recondition this product under this standard.

1 INSPECTION

1.1 Conduit Outlet Bodies and Components

- 1.1.1** Ensure that the product identifier marking is legible, if applicable.
- 1.1.2** Inspect for signs of damage, deterioration and defects.
- 1.1.3** Inspect for incorrect and missing parts.
- 1.1.4** Inspect to determine if proper cover will install and fit correctly.
- 1.1.5** Inspect gaskets for damage, brittleness and proper fit, as necessary.
- 1.1.6** Discard defective or substandard material.

II RECONDITIONING AND QUALITY CONTROL PROCEDURES

The following procedures are in a recommended order and are required to recondition this product. PEARL recognizes that, based upon actual product design and/or as found condition, some of these procedures may not be applicable.

1 RECONDITIONING

1.1 Conduit Outlet Bodies and Components

- 1.1.1** Clean all parts.
- 1.1.2** Refinish, as necessary.
- 1.1.3** Repair damaged PVC coating with approved PVC patch, as necessary.
- 1.1.4** Repair or replace damaged, defective, incorrect or missing component parts.
- 1.1.5** Repair or replace damaged, substandard or missing gaskets, as necessary.
- 1.1.6** Repair or replace damaged or incorrect product identifier to reflect proper information.

1.2 Packaging and Labeling

- 1.2.1** Ensure that the package label is complete, correct and legible.

III PEARL CERTIFICATION

This product has now been reconditioned under the PEARL Reconditioning Standard. The PEARL label and/or seal may be placed on it or its packaging.