

<b>PEARL Reconditioning Standards</b>			
<b>WIRE AND CABLE INSULATION RESISTANCE TEST VALUES</b>	Revision		
	Reference	Number	Date
	<b>6009</b>	5	11-2008

## **TABLE 9**

### **Wire and Cable Insulation Resistance Test Values**

Voltage Rating Of Wire Or Cable	Minimum dc Test Voltage	Minimum Megohms
0 - 600	500	500
601 – 5,000	1,000	5,000
5,001 – 15,000	2,500	25,000
15,001 – 69,000	5,000	50,000